中国国家强制性产品认证证书

证书编号：2024010304673109

认证委托人名称及地址

Siemens AG

Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

生产者名称及地址

Siemens AG

Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

生产企业名称及地址

Siemens Ltd.

Kalwa Works,Thane Belapur Road, Opp.Airoli Railway Station,Airoli,Thane,Thane,MAHARASHTRA,400708, India

产品名称和系列、型号、规格

接触器

3RT201...；详见附页

产品标准和技术要求

GB/T 14048.4-2020

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》（CNCA-C03-02:2024）的要求，特发此证。

发证日期：2026 年 05 月 27 日 **有效期至：**2029 年 08 月 19 日

本证书为变更证书，证书首次颁发日期：2024 年 08 月 20 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，也可在认监委网站（www.cnca.gov.cn）查询。

签发：

中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

中国国家强制性产品认证证书

证书编号：2024010304673109

3RT201… Ui:690V;Uimp:6kV; Ith:18A(3RT2015), 22A(3RT2016, 3RT2017, 3RT2018); 3RT2015: AC-1:Ue/Ie:AC690V/18A AC-3/AC-3e:Ue/Ie:AC690V/4.9A, AC500V/6A, AC400V/7A, AC230V/7A; 3RT2016: AC-1:Ue/Ie:AC690V/22A AC-3/AC-3e:Ue/Ie:AC690V/6.7A, AC500V/7.7A, AC400V/9A, AC230V/9A; 3RT2017: AC-1:Ue/Ie:AC690V/22A AC-3/AC-3e:Ue/Ie:AC690V/6.7A, AC500V/9.2A, AC400V/12A, AC230V/12A; 3RT2018: AC-1:Ue/Ie:AC690V/22A AC-3/AC-3e:Ue/Ie:AC690V/8.9A, AC500V/12.4A, AC400V/16A, AC230V/16A; 使用类别:AC-1,AC-3,AC-3e; Us:
100V,110V,125V,198V,200V,220V,400V,400V(50Hz);
24V,100~110V,120V,208V,200~220V,240V,400~440V,600V,277V,480V,347V(60Hz); 24V,42V,110V,48V,120V,208V,220V,230V,380V,500V,240V,400V(50/60Hz);
DC12V,DC24V,DC42V,DC60V,DC80V,DC110V,DC125V,DC72V,DC220V,DC250V,DC230V,DC48V; 极数:3P;IP20;适用频率:50/60Hz; 配用的辅助触头:1NO,1NC,可扩展至 4NO,4NC: Ith:10A;Ui:690V;Uimp:6kV; 侧面安装的辅助触头:CCC 证书: 2024010305673126:
3RH2911/3RH6911-DA..:AC-12:24V/10A,230V/10A;AC-15:24V/6A,230V/6A;400V/3A,500V/2A,690V/1A;
DC-13:24V/6A,60V/2A,125V/0.9A,250V/0.3A,230V/0.3A,600V/0.1A;
3RH2911/3RH6911-DE..:AC-14:60V/0.3A;DC-13:60V/0.3A; 顶部安装的辅助触头:CCC 证书: 2024010305672858:
3RH2911/3RH6911-A/B..:AC-12:24V/10A,230V/10A;AC-15:24V/6A,230V/6A,400V/3A,500V/2A,690V/1A;
DC-13:24V/6A,60V/2A,125V/0.9A,250V/0.3A,220V/0.25A,600V/0.1A;
3RH2911/3RH6911-F/G/H/L/M..:AC-12:24V/10A,230V/10A;AC-15:24V/6A,400V/3A,500V/2A,690V/1A;
DC-13:24V/6A,60V/2A,125V/0.9A,250V/0.3A,230V/0.3A,600V/0.1A;
3RH2911/3RH6911-N..:AC-14:60V/0.3A;DC-13:60V/0.3A; 内置辅助触头:
AC-12:230V/10A;AC-15:24-230V/10A,400V/3A,690V/1A;
DC-13:24V/10A,60V/2A,125V/0.9A,250V/0.3A,600V/0.1A

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010304673109

3.3 型号的解释:

3RT20	15	-	1	A	P0	1	-0CC0
I	II		III	IV	V	VI	VII

I. Basic Type 基本型号

3RT20 - Motor contactor Sirius Innovation，3NO main contacts

Sirius Innovation 系列接触器，3 常开主触头

II. Size S00 S00 框架

15 - 3 kW/400V

16 - 4 kW/400V

17 - 5.5 kW/400V

18 - 7.5 kW/400V

III. Type of Terminals 接线端子类型

-1 - Screw Terminal for main and auxiliary contacts 主触头和辅助触头锣丝接线端子

IV. Operating system 操作系统

A - AC operating system 交流操作系统

B - DC operating system 直流操作系统

V. Operating voltage 操作电压（See Table 2）

VI. Auxiliary Contact Arrangements 辅助触头组合

1 - 1 normally open 1 常开

2 - 1 normally closed 1 常闭

VII. Suffix letters and/or numbers specified commercial variations – Optional

商业用途的后缀字母和/或数字– 可选项

For example: 例如

-0CC0 -	contactor with communication interface 带有通讯接口的接触器
-0LA0 or 0LA1 -	contactors with factory assembled resistor 安装电阻器的接触器
-0LA2 or 2LA2 -	contactors with electronic coil control
-0KT0 -	contactor without factory assembled auxiliary contacts 安装辅助触头的接触器
-1AA0-	contactor for vertical site
-2AA0-	contactor for upside down site
-3MA0 -	contactor with top mounted auxiliary contact, not removable 顶部固定安装辅助触头的接触器
-8A -	Manufacturers identification for logistic purposes 物流管理的制造商识别标志
-ZX.. -	Multiple-unit packing
-ZW..-	Reusable packing

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE
中国质量认证中心有限公司
http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010304673109

NAME AND ADDRESS OF THE APPLICANT

Siemens AG

Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

Siemens AG

Werner-von-Siemens Strasse 48, D-92220 Amberg, Germany

NAME AND LOCATION OF THE FACTORY

Siemens Ltd.

Kalwa Works,Thane Belapur Road, Opp.Airoli Railway Station,Airoli,Thane,Thane,MAHARASHTRA,400708, India

PRODUCT NAME,MODEL AND SPECIFICATION

Contactor

3RT201…；See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.4-2020

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: May.27,2026 **Valid until:** Aug.19,2029

Date of original issued: Aug.20,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE:

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304673109

3RT201… Ui:690V;Uimp:6kV; Ith:18A(3RT2015), 22A(3RT2016, 3RT2017, 3RT2018); 3RT2015: AC-1:Ue/Ie:AC690V/18A AC-3/AC-3e:Ue/Ie:AC690V/4.9A, AC500V/6A, AC400V/7A, AC230V/7A; 3RT2016: AC-1:Ue/Ie:AC690V/22A AC-3/AC-3e:Ue/Ie:AC690V/6.7A, AC500V/7.7A, AC400V/9A, AC230V/9A; 3RT2017: AC-1:Ue/Ie:AC690V/22A AC-3/AC-3e:Ue/Ie:AC690V/6.7A, AC500V/9.2A, AC400V/12A, AC230V/12A; 3RT2018: AC-1:Ue/Ie:AC690V/22A AC-3/AC-3e:Ue/Ie:AC690V/8.9A, AC500V/12.4A, AC400V/16A, AC230V/16A; Utilization Category:AC-1,AC-3,AC-3e; Us:
100V,110V,125V,198V,200V,220V,400V,400V(50Hz);
24V,100~110V,120V,208V,200~220V,240V,400~440V,600V,277V,480V,347V(60Hz);
24V,42V,110V,48V,120V,208V,220V,230V,380V,500V,240V,400V(50/60Hz);
DC12V,DC24V,DC42V,DC60V,DC80V,DC110V,DC125V,DC72V,DC220V,DC250V,
DC230V,DC48V; pole:3P;IP20;50/60Hz; Accessory auxiliary contact:1NO,1NC,Can be extended to4NO,4NC: Ith:10A;Ui:690V;Uimp:6kV; Side-mounted auxiliary contact:CCC No.: 2024010305673126:
3RH2911/3RH6911-DA..:AC-12:24V/10A,230V/10A;AC-15:24V/6A,230V/6A;400V/3A,500V/2A,690V/1A;
DC-13:24V/6A,60V/2A,125V/0.9A,250V/0.3A,230V/0.3A,600V/0.1A;
3RH2911/3RH6911-DE..:AC-14:60V/0.3A;DC-13:60V/0.3A; Top-mounted auxiliary contact:CCC No.: 2024010305672858:
3RH2911/3RH6911-A/B..:AC-12:24V/10A,230V/10A;AC-15:24V/6A,230V/6A,400V/3A,500V/2A,690V/1A;
DC-13:24V/6A,60V/2A,125V/0.9A,250V/0.3A,220V/0.25A,600V/0.1A;
3RH2911/3RH6911-F/G/H/L/M..:AC-12:24V/10A,230V/10A;AC-15:24V/6A,400V/3A,500V/2A,690V/1A;
DC-13:24V/6A,60V/2A,125V/0.9A,250V/0.3A,230V/0.3A,600V/0.1A;
3RH2911/3RH6911-N..:AC-14:60V/0.3A;DC-13:60V/0.3A; auxiliary contact:
AC-12:230V/10A;AC-15:24-230V/10A,400V/3A,690V/1A;
DC-13:24V/10A,60V/2A,125V/0.9A,250V/0.3A,600V/0.1A

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304673109

3.3 型号的解释:

3RT20	15	-	1	A	P0	1	-0CC0
I	II		III	IV	V	VI	VII

I. Basic Type 基本型号

3RT20 - Motor contactor Sirius Innovation，3NO main contacts

Sirius Innovation 系列接触器，3 常开主触头

II. Size S00 S00 框架

15 - 3 kW/400V

16 - 4 kW/400V

17 - 5.5 kW/400V

18 - 7.5 kW/400V

III. Type of Terminals 接线端子类型

-1 - Screw Terminal for main and auxiliary contacts 主触头和辅助触头锣丝接线端子

IV. Operating system 操作系统

A - AC operating system 交流操作系统

B - DC operating system 直流操作系统

V. Operating voltage 操作电压（See Table 2）

VI. Auxiliary Contact Arrangements 辅助触头组合

1 - 1 normally open 1 常开

2 - 1 normally closed 1 常闭

VII. Suffix letters and/or numbers specified commercial variations – Optional

商业用途的后缀字母和/或数字– 可选项

For example: 例如

-0CC0 -	contactor with communication interface 带有通讯接口的接触器
-0LA0 or 0LA1 -	contactors with factory assembled resistor 安装电阻器的接触器
-0LA2 or 2LA2 -	contactors with electronic coil control
-0KT0 -	contactor without factory assembled auxiliary contacts 安装辅助触头的接触器
-1AA0-	contactor for vertical site
-2AA0-	contactor for upside down site
-3MA0 -	contactor with top mounted auxiliary contact, not removable 顶部固定安装辅助触头的接触器
-8A -	Manufacturers identification for logistic purposes 物流管理的制造商识别标志
-ZX.. -	Multiple-unit packing
-ZW..-	Reusable packing

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304673109

This page is attached to the certificate and should be used at the same time as the certificate page.

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

http://www.cqc.com.cn Building 5, Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86 10 83886666