AIRMAIL/SPEED POST

Our Ref: FMCD (Scheme-X)/**A-4106600**

Date: 05-01-2026

Subject: Grant of BIS Product Certification Licence Number **L-4100288693** as per IS/IEC 60947-4-1: 2018

Siemens Aktiengesellschaft
Werner-von-Seimens Str. 48, 92224,
Amberg, Bavaria-Germany

Dear Sir(s),

With reference to your application **(A-4106600)**, we are pleased to inform you that the licence has been granted to you in accordance with conformity assessment Scheme-X of BIS to use the Standard Mark in respect of the followings:

Product:

(i) Grade
(ii) Class
(iii) Type
(iv) Variety

→ Please refer Annexure-1

1. The number assigned to this licence is **L- 4100288693** which has been made operative from **22-12-2025** and is valid up to **21-12-2028.** The licence number shall invariably be referred to in your future correspondence.
2. The licence is granted on the explicit condition that you shall mark entire production under scope of licence with Standard Mark and maintain conformity to the relevant Indian Standards. Accordingly, you shall cover the entire production under scope of licence with Standard Mark and maintain conformity to the relevant Indian Standards. In addition, you shall display the BIS product certification licence held by you prominently at your premises and also mention

the BIS product certification licence held by you in your commercial advertisements.

3. According to notification No. CMD-2/G-18 dated 24/05/2023, the certification fee is payable by you with effect from **22/12/2025** for the period of validity of the licence in advance. This certification fee is payable by you regardless of the fact whether you actually mark your product or not with the Standard Mark. Our Receipt No. **HQNDNT2025001392** dated **11-07-2025** is enclosed.

4. The in-house quality assurance plan submitted by you will have to be implemented by your organisation strictly and completely. The supervision of the operation of this quality assurance plan shall be done by a person responsible for the quality control function in your organisation. Kindly inform us the name and designation of the person who will be held responsible for the operation and maintenance of the Scheme. Any future change in this respect will have to be communicated by you to us as and when these take place.

5. We are enclosing a sheet giving the preferred dimensions of the Standard Mark to enable you to prepare the designs of the Standard Mark for marking the above product Photographic reduction in any size is permissible. This will ensure the relative proportions of the different dimensions maintained. Preferred dimensions be used as far as possible.

6. On commencement of marking of your product for which you are licensed, you shall advertise your product with Standard Mark in various media only during the validity of your licence. The use of Standard Mark on letterheads and publicity literature is permitted only on receipt of your assurance that in the event of cancellation or lapsing of your licence, the Standard Mark on your letterheads, publicity literatures etc. will be destroyed/obliterated.

7. You are also advised to make yourself and other employees in your organisation aware about the provisions of the BIS Act, 2016 and Rules and Regulations framed thereunder especially the implications in case of any intentional or unintentional non-adherence.

8. The Licence is granted for your manufacturing premises situated at **Siemens Aktiengesellschaft Werner-von-Seimens Str. 48, 92224, Amberg, Bavaria-Germany** and the rights and privileges under the licence shall not be exercised by any other firm/company/factory, etc. This licence is not transferable. In the event of shifting of the manufacturing and testing equipment from the licensed premises to some other place, use of Standard Mark shall be stopped till the new premises are inspected and found to be satisfactory by BIS in respect of manufacturing and testing facilities available there and the address of the new premises is enclosed in the licence.

9. You are requested to furnish the Agreement for grant of licence, duly executed on a **non-judicial stamp papers of Rs.100.00,** incorporating the terms and conditions of the BIS certification marks licence granted to you, as per the format enclosed within 15 days of issue of the letter.

10. You are required to furnish a **Bank Guarantee for USD 10,000 (US Dollars ten Thousand only)** having validity of six months more than the validity of the licence issued by any Bank to the satisfaction of BIS by way of performance security Bond for due compliance of the provisions of the BIS Act, 2016, the Rules and Regulations framed thereunder, and the terms and conditions of this agreement, as per format enclosed herewith within 45 days of issue of this letter.

11. You are also required to submit an **Indemnity Bond** to declare BIS harmless and indemnified in respect of any third-party claims with regard to conformity of your products to the correspondence Indian Standards under the afore-mentioned BIS licence granted to you, as per format enclosed herewith within 15 days of issue of this letter.

12. Kindly acknowledge receipt of this letter.

Notes: (1) Performance Bank Guarantee (PBG) (para 11 above) shall be issued by any Bank having RBI approved branch in INDIA. Original PBG shall be endorsed & routed / forwarded through the Indian branch.

(2) Kindly note that if the time norms indicated in para 10, 11, and 12 above are not complied with, BIS may be constrained to take actions as per norms including stoppage of marking for the licence

Thanking you.

Yours Faithfully

(Manish Kumar)
Sc-E & Head (FMCD)

Copy to: Mr. Hemant Narvekar
Kalwa Works, 48 Thane Belapur Road, Airoli Node,
Navi Mumbai- 400708

Annex-1_Scope of License_Power Contactor

License is granted to use Standard Mark as per IS/IEC 60947 (Part 4 / Section 1): 2018 with the following scope:"	
Name of the product:	Low-Voltage Switchgear and Controlgear Part 4 Contactors and Motor-Starters Section 1 Electromechanical Contactors and Motor-Starters
Equipment Types: (Cl. 5.2.1)	- Contactor 3RT201, 3RT231, 3RT251
Rated voltages (Cl. 5.3.1)	- Rated operational voltage (U_e) 690 V - Rated insulation voltage (U_i) 690 V - Rated impulse withstand voltage (U_{imp}) 6 kV
Rated Current (Cl. 5.3.2)	- Rated operational currents (I_e) 3RT201: AC-3/AC-3e up to 16 A 3RT231: AC-1 up to 22 A 3RT251: AC-3 up to 9 A (NO) / 16 A (NC) - Conventional free air thermal current (Ith) - 3RT201: up to 16 A 3RT231: up to 22 A 3RT251: up to 9 A (NC) / 16 A (NO)
Rated Frequency	- 50 Hz or 60 Hz
Number of poles: (Cl. 5.2.2)	- 3RT201: 3 3RT231: 4 3RT251: 4
Kind of current (Cl. 5.2.3)	- AC
Interrupting medium (Cl. 5.2.4)	- air
Method of operation (Cl. 5.2.5.1)	- electromagnetically operated
Method of control ~~(Cl. 5.2.5.1~~ Cl. 5.2.5.2)	- non-automatic
Utilization Categories (Table 1)	- 3RT201: AC-1, AC-3, AC-3e - 3RT231: AC-1 - 3RT251: AC-1, AC-3
Rated duties (Cl. 5.3.4)	- Eight-hour duty
Type of coordination with short-circuit protective devices (Cl. 8.2.5)	- type 1 - type 2
Degree of Protection	- IP 20 (Front)

Control circuits (if applicable) (Cl. 5.5)	Type of current – ac or dc - rated frequency (for ac) or direct current; rated control circuit voltage Uc: 50 Hz, 60 Hz or 50/60 Hz, dc ac: 24 ... 600 V dc: 12 ... 240 V
Auxiliary circuits (if applicable) (Cl. 5.6)	- Form X and Y
Types of relay or release, if applicable (For relay and release of overload relays and motor protective switching device (MPSD)) (Cl. 5.7.2)	N / A
Additional Features *	
Electromagnetic Compatibility (EMC) (Cl. 8.3)	Not Tested
Auxiliary contact linked with power contact (mirror contact) (Annex – F)	Suitable
Contactors for use with semiconductor-controlled motor load (Annex – I)	Not suitable
Uses in Functional safety applications (Annex – K)	Not suitable
Safety applications and especially in explosive atmospheres (Annex – L)	Not suitable
Use in Photovoltaic (PV) DC applications (Annex – M)	Not suitable
Equipment with Protective Separation (Annex – N)	Not tested
Intended for connection of Aluminium Conductors (Annex – E)	Not suitable

Annex-1_Scope of License_Power Contactor

License is granted to use Standard Mark as per IS/IEC 60947 (Part 4 / Section 1): 2018 with the following scope:"	
Name of the product:	Low-Voltage Switchgear and Controlgear Part 4 Contactors and Motor-Starters Section 1 Electromechanical Contactors and Motor-Starters
Equipment Types: (Cl. 5.2.1)	- Contactor type 3RT262
Rated voltages (Cl. 5.3.1)	- Rated operational voltage (U_e) 690 V - Rated insulation voltage (U_i) 690 V - Rated impulse withstand voltage (U_{imp}) 6 kV
Rated Current (Cl. 5.3.2)	- Rated operational powers: 3RT262: AC-6b up to 33kVar - Conventional free air thermal current (Ith) - 3RT262: up to 64,4 A
Rated Frequency	- 50 Hz or 60 Hz
Number of poles: (Cl. 5.2.2)	- 3
Kind of current (Cl. 5.2.3)	- AC
Interrupting medium (Cl. 5.2.4)	- air
Method of operation (Cl. 5.2.5.1)	- electromagnetically operated
Method of control (~~Cl. 5.2.5.1~~ Cl. 5.2.5.2)	- non-automatic
Utilization Categories (Table 1)	- AC-6b
Rated duties (Cl. 5.3.4)	- Eight-hour duty
Type of coordination with short-circuit protective devices (Cl. 8.2.5)	- type 1
Degree of Protection	- IP 20 (Front)
Control circuits (if applicable) (Cl. 5.5)	Type of current – ac or dc - rated frequency (for ac) or direct current; rated control circuit voltage Uc: 50 Hz, 60 Hz or 50/60 Hz, dc ac: 24 … 600 V dc: 12 … 240 V

Auxiliary circuits (if applicable) (Cl. 5.6)	- Form X and Y
Types of relay or release, if applicable (For relay and release of overload relays and motor protective switching device (MPSD)) (Cl. 5.7.2)	N / A
Additional Features *	
Electromagnetic Compatibility (EMC) (Cl. 8.3)	Not Tested
Auxiliary contact linked with power contact (mirror contact) (Annex – F)	Suitable
Contactors for use with semiconductor-controlled motor load (Annex – I)	Not suitable
Uses in Functional safety applications (Annex – K)	Not suitable
Safety applications and especially in explosive atmospheres (Annex – L)	Not suitable
Use in Photovoltaic (PV) DC applications (Annex – M)	Not suitable
Equipment with Protective Separation (Annex – N)	Not tested
Intended for connection of Aluminium Conductors (Annex – E)	Not suitable

Annex-1_Scope of License_Power Contactor

License is granted to use Standard Mark as per IS/IEC 60947 (Part 4 / Section 1): 2018 with the following scope:"	
Name of the product:	Low-Voltage Switchgear and Controlgear Part 4 Contactors and Motor-Starters Section 1 Electromechanical Contactors and Motor-Starters
Equipment Types: (Cl. 5.2.1)	- Contactor type 3RT261
Rated voltages (Cl. 5.3.1)	- Rated operational voltage (U_e) 690 V - Rated insulation voltage (U_i) 690 V - Rated impulse withstand voltage (U_{imp}) 6 kV
Rated Current (Cl. 5.3.2)	- Rated operational powers 3RT261: AC-6b up to 12,5kVar - Conventional free air thermal current (Ith) - 3RT261: up to 24,4A
Rated Frequency	- 50 Hz or 60 Hz
Number of poles: (Cl. 5.2.2)	- 3
Kind of current (Cl. 5.2.3)	- AC
Interrupting medium (Cl. 5.2.4)	- air
Method of operation (Cl. 5.2.5.1)	- electromagnetically operated
Method of control (~~Cl. 5.2.5.1~~ Cl. 5.2.5.2)	- non-automatic
Utilization Categories (Table 1)	- AC-6b
Rated duties (Cl. 5.3.4)	- Eight-hour duty
Type of coordination with short-circuit protective devices (Cl. 8.2.5)	- type 1
Degree of Protection	- IP 20 (Front)
Control circuits (if applicable) (Cl. 5.5)	Type of current – ac or dc - rated frequency (for ac) or direct current; rated control circuit voltage Uc: 50 Hz, 60 Hz or 50/60 Hz, dc ac: 24 … 600 V dc: 12 … 240 V

Auxiliary circuits (if applicable) (Cl. 5.6)	- Form X and Y
Types of relay or release, if applicable (For relay and release of overload relays and motor protective switching device (MPSD)) (Cl. 5.7.2)	N / A
Additional Features *	
Electromagnetic Compatibility (EMC) (Cl. 8.3)	Not Tested
Auxiliary contact linked with power contact (mirror contact) (Annex – F)	Suitable
Contactors for use with semiconductor-controlled motor load (Annex – I)	Not suitable
Uses in Functional safety applications (Annex – K)	Not suitable
Safety applications and especially in explosive atmospheres (Annex – L)	Not suitable
Use in Photovoltaic (PV) DC applications (Annex – M)	Not suitable
Equipment with Protective Separation (Annex – N)	Not tested
Intended for connection of Aluminium Conductors (Annex – E)	Not suitable

Annex-1_Scope of License_Power Contactor

License is granted to use Standard Mark as per IS/IEC 60947 (Part 4 / Section 1): 2018 with the following scope:"	
Name of the product:	Low-Voltage Switchgear and Controlgear Part 4 Contactors and Motor-Starters Section 1 Electromechanical Contactors and Motor-Starters
Equipment Types: (Cl. 5.2.1)	- Contactor type 3RT202, 3RT232, 3RT252
Rated voltages (Cl. 5.3.1)	- Rated operational voltage (U_e) 690 V - Rated insulation voltage (U_i) 690 V - Rated impulse withstand voltage (U_{imp}) 6 kV
Rated Current (Cl. 5.3.2)	- Rated operational currents (I_e) 3RT202: AC-3/AC-3e up to 38 A 3RT232: AC-1 up to 50 A 3RT252: AC-3 up to 25 A (NO) / 25 A (NC) - Conventional free air thermal current (Ith) - 3RT202: up to 38 A 3RT232: up to 50 A 3RT252: up to 25 A (NC) / 25 A (NO)
Rated Frequency	- 50 Hz or 60 Hz
Number of poles: (Cl. 5.2.2)	- 3RT202: 3 3RT232: 4 3RT252: 4
Kind of current (Cl. 5.2.3)	- AC
Interrupting medium (Cl. 5.2.4)	- air
Method of operation (Cl. 5.2.5.1)	- electromagnetically operated
Method of control ~~(Cl. 5.2.5.1~~ Cl. 5.2.5.2)	- non-automatic
Utilization Categories (Table 1)	- 3RT202: AC-1, AC-3, AC-3e 3RT232: AC-1 **3RT232.-…..-4AA0:** AC-1, AC-3 3RT252: AC-1, AC-3
Rated duties (Cl. 5.3.4)	- Eight-hour duty
Type of coordination with short-circuit protective devices (Cl. 8.2.5)	- type 1 and type 2
Degree of Protection	- IP 20 (Front)

Control circuits (if applicable) (Cl. 5.5)	Type of current – ac or dc - rated frequency (for ac) or direct current; rated control circuit voltage Uc: 50 Hz, 60 Hz or 50/60 Hz, dc ac: 24 ... 600 V dc: 12 ... 250 V
Auxiliary circuits (if applicable) (Cl. 5.6)	- Form X and Y
Types of relay or release, if applicable (For relay and release of overload relays and motor protective switching device (MPSD)) (Cl. 5.7.2)	N / A
Additional Features *	
Electromagnetic Compatibility (EMC) (Cl. 8.3)	Not Tested
Auxiliary contact linked with power contact (mirror contact) (Annex – F)	Suitable
Contactors for use with semiconductor-controlled motor load (Annex – I)	Not suitable
Uses in Functional safety applications (Annex – K)	Not suitable
Safety applications and especially in explosive atmospheres (Annex – L)	Not suitable
Use in Photovoltaic (PV) DC applications (Annex – M)	Not suitable
Equipment with Protective Separation (Annex – N)	Not tested
Intended for connection of Aluminium Conductors (Annex – E)	Not suitable